## GROUND WATER SURVEY CONSULTANCY GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

#### GEO-PHYSICAL WELL ELECTOLOGGING REPORT

Ref No:- 339

₩

Date: - 19-01-2022

#### NAME OF SITE

GRAM PANCHAYAT- Chaanda

BLOCK-Sindhauli

DISTT- Shahjanhapur

#### NAME OF AGENCY

M/s NCC Ltd. Shahjanhapur



#### GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M): 9412260823, 9794625420, 9761163000, Email: gwsc\_agra@yahoo.com

ISO; 9001: 2015

Ground Water Survey Consultancy

### REPORT ON GEOPHYSICAL WELL LOGGING

# GRAM PANCHAYAT- CHAANDA, BLOCK- SINDHAULI DISTT- SHAHJANHAPUR UNDER JAL JIVAN MISSION

#### Introduction:

A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 135 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahajanhapur.

On the request of M/S NCC Ltd., Shahajanhapur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 19.Jan.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major equifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Defth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 8	3	Clay kankar	
3.	8 - 17	9	Medium sand	
4.	17 - 30	13	Clay kankar	
5.	30 - 38	8	Fine sand	Good
6.	38 - 45	7	Clay kankar	
7.	45 - 54*	9	Medium sand	Good
8.	54 - 60	6	Clay kankar	
9.	60 - 77*	17	Medium sand	Good
10.	77 - 85	8	Clay kankar	
11.	85 - 110*	25	Medium sand & Kankar	Good
12.	110 - 118	8	Clay kankar	The state of the s
13.	118 - 127*	9	Fine to Medium sand	Good
14.	127 - 135	8	Clay kankar	



#### Conclusions and Recommendations :-

- 1. The Lithology broadly tallies with that of drill cutting starta chart.
- 2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
- 3. The Quality of water is expected Good.
- 4. Expected discharge is 1100 to 1200 L.P.M.
- 5. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
- 6. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.



**Ground Water Survey Consultancy** 

