GROUND WATER SURVEY CONSULTANCY GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

是認及政策和出身的文化。在中央共和国的政策的政策和政策的政策和政策的对象,但是对政策的对象的对象的对象

GEO-PHYSICAL WELL ELECTOLOGGING REPORT

Ref No:- 340

Date: - 19-01-2022

NAME OF SITE

GRAM PANCHAYAT- Mahmoodpur

BLOCK-Nigohi DISTT-Shahjanhapur

NAME OF AGENCY

M/s NCC Ltd. Shahjanhapur



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M): 9412260823, 9794625420, 9761163000, Email: gwsc_agra@yahoo.com

ISO; 9001: 2015

Ground Water Survey Consultancy

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- MAHMOODPUR, BLOCK- NIGOHI, DISTT- SHAHJANHAPUR UNDER JAL JIVAN MISSION

Introduction:

A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 140 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahajanhapur.

On the request of M/S NCC Ltd., Shahajanhapur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 19.Jan.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major equifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Defth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 18	13	Clay kankar	
3.	18 - 29	11	Medium sand	
. 4.	29 - 33	4	Clay kankar	
5.	33 - 43	10	Medium sand	Good
6.	43 - 49	6	Clay kankar	
7.	49 - 55*	6	Medium sand	Good
8.	55 - 70	15	Clay kankar	
9.	70 - 100*	30	Medium sand	Good
10.	100 - 108	8	Clay kankar	
11.	108 - 120*	12	Medium sand	Good
12.	120 - 130	10	Sandy clay	
13.	130 - 140*	10	Fine to Medium sand	Good

Ground Water Survey Consultancy

Conclusions and Recommendations :-

- 1. The Lithology broadly tallies with that of drill cutting starta chart.
- 2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
- 3. The Quality of water is expected Good.
- 4. Expected discharge is 1100 to 1200 L.P.M.
- 5. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
- 6. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.



Ground Water Survey Consultancy

