

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date 22.10.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency NCC Shahjahanpur
 Village Sena Khora Block Madmalpur
 District Shahjahanpur Logging Depth 125 m
 Drilling Depth 130 m Water Level 9 m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-10	fine Sand	
3	10-15	clay	
4	15-22	Medium Sand	Good
5	22-26	clay	
6	26-30	v. fine sand	
7	30-37	clay kankar	
8	37-47	kankar	
9	47-61	medium sand	Good
10	61-68	clay kankar	
11	68-73	Medium Sand	Good
12	73-80	clay kankar	
13	80-95	Med Sand etc	Good
14	95-106	clay kankar	
15	106-118	Medium Sand	Good
16	118-125	clay kankar	
17			
18			
19			
20			
21			
22			
23			



*Expected Water Bearing Zone

For Ground Water Survey Consultancy

Sravya
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.