

STIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794825420, Email : gwsc_agra@yahoo.com

No.


Date 26.1.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency MCC Shejannahapur
 Village Raheriya Block Sindkhauri
 District Shejannahapur Logging Depth 123 mt
 Drilling Depth 126 mt Water Level 6 mt

| S.No | Depth in Mtr. | Lithology | Expected Water Quality |
|------|---------------|------------------|------------------------|
| 1 | 0 - 5 | Surface Soil | |
| 2 | 5 - 22 | Fine to Med Sand | |
| 3 | 22 - 27 | clay lenses | |
| 4 | 27 - 50 | Medium Sand | Med + Good |
| 5 | 50 - 54 | clay lenses | |
| 6 | 54 - 67 | Medium Sand | Med + Good |
| 7 | 67 - 72 | clay lenses | |
| 8 | 72 - 94 | Medium Sand | Med + Good |
| 9 | 94 - 98 | clay lenses | |
| 10 | 98 - 110 | Medium Sand | Med to Good |
| 11 | 110 - 123 | clay lenses | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |
| 21 | | | |
| 22 | | | |
| 23 | | | |



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations in

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.