

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Ph : 0562 - 4058694 (M) 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com


Ref No.....

Date 24.4.22

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency MCC Shahjanhabur  
Village Mathang Block Madanapur  
District Shahjanhabur Logging Depth 130mts  
Drilling Depth 130mts Water Level 8mts

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface soil	
2	5 - 10	Dry sand	
3	10 - 20	Clay kankar	
4	20 - 36	Sandy clay	
5	36 - 40	Clay kankar	
6	40 - 47	Sandy clay	
7	47 - 65'	Fine to med sand	Good
8	65 - 72	Clay kankar	
9	72 - 86'	Medium sand	Good
10	86 - 90	Kankar	
11	90 - 110'	Fine to med sand	Good
12	110 - 118	Clay kankar	
13	118 - 130	Fine sand	Good
14			
15			
16			
17			
18			
19			



\*Expected Water Bearing Zone

For Ground Water Survey Consultancy

*Suresh*  
Geophysicist

### Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations