

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

**GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS**

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
 Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com


Ref No. ....

Date: 10.6.23

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency - M.C. Shaljeethappa  
 Village - Baxkhada, Jaipur Block - Padmapur  
 District - Shaljeethappa Logging Depth - 140 mt  
 Drilling Depth - 140 mt Water Level - 12 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-15	Sand ch	
3	15-20	Fine Sand	
4	20-40	Medium Sand	Medium
5	40-45	clay loam	
6	45-50	Medium Sand	Medium
7	50-56	clay loam	
8	56-85	Medium Sand	Medium
9	85-91	clay loam	
10	91-106	Medium Sand	Medium
11	106-115	clay loam	
12	115-129	Medium Sand	Medium
13	129-131	clay loam	
14	131-138	Fine Sand	Medium
15	138-140	clay loam	
16			
17			
18			
19			
20			
21			
22			
23			



\* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Signature  
 Geophysicist

### Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.