



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.

Date 5/1/24

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency HCC Ltd Shahjehanpur
 Village Firozpur & Bellero Block Talhar
 District Shahjehanpur Logging Depth 120 mt
 Drilling Depth 120 mt Water Level 6 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 25	clay loam	
3	25 - 87	Medium Sandstone	Medium
4	87 - 92	clay loam	
5	92 - 115	Medium Sand	Medium
6	115 - 120	clay loam	
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Rajesh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigation