

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date 21/9/22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency..... NCS Shahjehanpur.....
 Village..... Mundiyra..... Block..... Kanli.....
 District..... Shahjehanpur..... Logging Depth..... 12.0m.....
 Drilling Depth..... 12.2m..... Water Level..... 11.2m.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-7	Dry Sand	
3	7-9	clay loam	
4	9-21	fine to med sand	
5	21-27	clay loam	
6	27-33	medium sand	Good
7	33-38	clay loam	
8	38-62	medium sand	Good
9	62-95	fine to med sand	Good
10	95-103	clay loam	
11	103-117	medium sand	Good
12	117-120	clay loam	
13			
14			
15			
16			
17			
18			
19			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Open Well, Rectification of Tubewells, Ground Water Investigations.