

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Ph : 0562 - 4058694 (M) 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

Ref No.....

Date 8.1.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Location - Block- Khudaganj
Village- Majhale District- Shahjehanpur
Drilling Depth- 135 mts Water Level- 12 mts

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-22	Sandy clay	
3	22-24	clay	
4	24-32	Fine sand	Good
5	32-35	clay loam	
6	35-40	Fine sand	Good
7	40-50	clay loam	
8	50-57	Fine to med. sand	Good
9	57-64	clay loam	
10	64-80	Fine to Medium sand etc	Good
11	80-98	Fine sand etc	Good
12	98-105	clay loam	
13	105-125	Fine to Medium sand	Good
14	125-135	clay loam	
15			
16			
17			
18			
19			

Expected Water Bearing Zone

For Ground Water Survey Consultancy

S. Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.