

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No.....

Date 2.9.22

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES


Name Of Agency- N.S.C. Shahjehanpur

Village- Saunphari Block- Khetar

District- Shahjehanpur Logging Depth- 140 mt

Drilling Depth- 142 mt Water Level- 9 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface soil	
2	5-15	Sandy clay	
3	15-21	clay loam	
4	21-45	medium sand	Good
5	45-65	clay loam	
6	65-79 <sup>m</sup>	medium sand	Good
7	79-82	clay loam	
8	82-94 <sup>m</sup>	medium sand	Good
9	94-104	clay loam	
10	104-111 <sup>m</sup>	medium sand	Good
11	111-117	clay loam	
12	117-135 <sup>m</sup>	medium sand	Good
13	135-140	clay loam	
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

*Sadant*  
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.