



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date... 09-04-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency..... M/s. Shahjahan.p.w.

Village -..... Rasia..... Block..... Sindauli.....

District..... Shahjahanpur..... Logging Depth..... 130 mtr.....

Drilling Depth..... 130 mtr..... Water Level..... 3 mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 16	clay Kankar	
3	16 - 20	Fine Sand	
4	20 - 28	clay Kankar	
5	28 - 40	Fine to med. Sand	Good
6	40 - 46	clay Kankar	
7	46 - 61*	medium Sand	Good
8	61 - 70	clay Kankar	
9	70 - 76*	Fine to med. Sand	Good
10	76 - 84	clay Kankar	
11	84 - 108*	medium Sand & Kank.	Good
12	108 - 115	clay Kankar	
13	115 - 130*	medium Sand	Good
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

UK
PT
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,