

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com


Ref No.....

Date...7.4.22.....

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency... M.C. Shahjehanpur.....  
Village... Uganpur..... Block... Banda.....  
District... Shahjehanpur..... Logging Depth... 140 mts.....  
Drilling Depth... 142 mts..... Water Level... 6 mts.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 15	Fine Sand	
3	15 - 32	clay kankar	
4	32 - 40	Medium Sand	Good
5	40 - 55	clay kankar	
6	55 - 63*	Medium sand	Good
7	63 - 67	clay kankar	
8	67 - 77*	Medium Sand	Good
9	77 - 105	clay kankar	
10	105 - 131*	Medium sand	Good
11	131 - 140	clay kankar	
12			
13			
14			
15			
16			
17			
18			
19			



\*Expected Water Bearing Zone

For Ground Water Survey Consultancy

*S. Singh*  
Geophysicist

### Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.