

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9781163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date 14.5.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency MCC Shahjehanpura
Village Verasia Block Hushtu
District Shahjehanpura Logging Depth 140 mts
Drilling Depth 141 mts Water Level 9 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface soil	
2	5-20	clay loam	
3	20-36	Medium Sand	Good
4	36-40	clay loam	
5	40-69	Medium Sand	Good
6	69-86	clay loam	
7	86-101	Medium Sand	Good
8	101-110	clay loam	
9	110-123	Medium Sand	Good
10	123-127	clay loam	
11	127-142	Sandstone	
12			
13			
14			
15			
16			
17			
18			
19			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Sanku
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.