



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date 20.4.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONNES

Name Of Agency- MCC Shahjehanpur
 Village- SP Vidya Nawaeda Block- Sindhaul
 District- Shahjehanpur Logging Depth- 129 mb
 Drilling Depth- 131 mb Water Level- 12 mb

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface soil	
2	5 - 20	fine sand	
3	20 - 27	clay loam	
4	27 - 65*	Medium Sand	Good
5	65 - 72	clay loam	
6	72 - 76	Sandy clay	
7	76 - 82	clay loam	
8	82 - 114*	Medium Sand	Good
9	114 - 120	clay loam	
10	120 - 125'	Medium Sand	Good
11	125 - 129	clay	
12			
13			
14			
15			
16			
17			
18			
19			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Susmita
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Discharge Well Rectification of Tubewells, Ground Water Investigations.