

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 8.12.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency NCC Shahjahanpur
 Village Vikrampur, Chokaura Block Nigohi
 District Shahjahanpur Logging Depth 130 mt
 Drilling Depth 130 mt Water Level 11 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface soil	
2	5 - 8	clay	
3	8 - 32	medium sand	Good
4	32 - 45	clay kankar	
5	45 - 53	medium sand	Good
6	53 - 58	clay kankar	
7	58 - 70	medium sand	Good
8	70 - 88	clay kankar	
9	88 - 114	medium sand	Good
10	114 - 116	kankar	
11	116 - 124	fine to med sand	Good
12	124 - 130	sandy clay	
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.