

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No.....

Date 15.7.23

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES


Name Of Agency- M.C.C. Shahjahanpura

Village - Silhua Block- Khuday

District- Shahjahanpura Logging Depth- 120 mt

Drilling Depth- 120 mt Water Level- 10 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-10	Dry Sand	
3	10-25	Fine to med Sand	
4	25-30	clay loam	
5	30-40	Medium Sand	Medium
6	40-48	clay loam	
7	48-70	Medium Sand + coarse lime	Medium
8	70-80	lime	
9	80-86"	Medium Sand	Medium
10	86-90	clay loam	
11	90-108"	Medium Sand	Medium
12	108-117	clay loam	
13	117-120"	Medium Sand	Medium
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

*Smit*  
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.