

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTROLOGGING REPORT

Ref No:- 538

Date:- 02-03-2022

NAME OF SITE

GRAM PANCHAYAT- Sunara Bujurg BLOCK- Powayan DISTT- Shahjanhapur

NAME OF AGENCY

M/s NCC Ltd.
Shahjanhapur



GROUND WATER SURVEY CONSULTANCY


Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- SUNARA BUJURG, BLOCK- POWAYAN
DISTT- SHAHJANHAPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 141 mtrs. depth. and Logged depth 140 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahajanhapur.

On the request of M/S NCC Ltd., Shahajanhapur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 02.Mar.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64). Lateral Details of major equifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 18	13	Fine sand	
3.	18 - 22	4	Clay kankar	
4.	22 - 39	17	Medium sand	Good
5.	39 - 50	11	Clay kankar	
6.	50 - 65*	15	Medium sand	Good
7.	65 - 72	7	Clay kankar	
8.	72 - 80*	8	Fine to Medium sand	Good
9.	80 - 90	10	Clay kankar	
10.	90 - 97*	7	Medium sand	Good
11.	97 - 101	4	Clay kankar	
12.	101 - 124*	23	Medium sand	Good
13.	124 - 127	3	Clay kankar	
14.	127 - 135*	8	Fine to Medium sand	Good
15.	135 - 140	5	Clay kankar	

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting starta chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. Expected discharge is 1000 to 1100 L.P.M.
5. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
6. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a
 NI6 (SN)
 N64(LN)
 LAT

Logging VI Sumaria
 Ewring Blvd.
 Pawayan Distt
 Shahjahanpur
 LOGGERSUP
 22 Mar 2022
 CS 01
 Utharsh Gupta (LG)

SP (m V)

