

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No.....


Date 8-12-22

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency NCC Shahjehanpur  
Village Peeru Block Powyan  
District Shahjehanpur Logging Depth 130 mt  
Drilling Depth 130 mts Water Level 9 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Snd	
2	5-22	fine to med Sand	
3	22-26	clay later	
4	26-45	Medium Sand	Medium
5	45-54	clay later	
6	54-61 <sup>0</sup>	Medium Sand	Medium
7	61-67	clay later	
8	67-73 <sup>0</sup>	Medium Sand	Medium
9	73-84	clay later	
10	84-105 <sup>0</sup>	Medium Sand	Medium
11	105-113	clay later	
12	113-122 <sup>0</sup>	Med Sand & clay	Medium
13	122-130	clay later	
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Sand  
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.