



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date..20-01-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency-.....N.S. Shahjahanpur.....
 Village -.....Purayu..... Block-.....Tilhar.....
 District-.....Shahjahanpur..... Logging Depth-.....120 mtr.....
 Drilling Depth-.....133 mtr..... Water Level-.....9 mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-12	Fine Sand	
3	12-18	clay Kankar	
4	18-40	Fine to Med. Sand	Good
5	40-45	clay Kankar	
6	45-51	medium Sand & Kan.	Good
7	51-55	clay Kankar	
8	55-67*	medium Sand	Good
9	67-70	clay Kankar	
10	70-83*	medium Sand & Kan.	Good
11	83-87	clay Kankar	
12	87-92	Kankar	
13	92-97	clay Kankar	
14	97-107*	medium Sand & Kan.	Good
15	107-120	clay Kankar	
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

U12
S.P.
Geophysicist

Specializations In