

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com


Ref No.....

Date 26-12-22

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency- MCC Shahjehanpur  
Village - Markandapur Block- Jaitpur  
District- Shahjehanpur Logging Depth- 120mtr  
Drilling Depth- 125 mtr Water Level- 11 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-12	clay kaon	
3	12-35	Medium Sand	Medium
4	35-42	clay kaon	
5	42-63	Medium Sand	Medium
6	63-65	kaon	
7	65-78	Medium Sand	Medium
8	78-84	clay kaon	
9	84-97	Medium Sand	Medium
10	97-104	clay kaon	
11	104-115	Medium Sand	Medium
12	115-120	Sandy clay	
13			
14			
15			
16			
17			
18			
19			



\* Expected Water Bearing Zone

For Ground Water Survey Consultancy

*Suresh*  
Geophysicist

### Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.