

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 22.9.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- H.C.S. Shahjehanpaur
 Village - Sitting Khara Block- Dadant
 District- Shahjahanpaur Logging Depth- 125m
 Drilling Depth- 135m Water Level- 6m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-8	clay konker	
3	8-37	fine + med sand	Good
4	37-41	clay konker	
5	41-51	Medium Sand	Good
6	51-77	clay konker	
7	77-90*	Medium Sand	Good
8	90-97	clay konker	
9	97-118*	fine + med sand	Good
10	118-125	Sandy clay	
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Srivastava
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.