

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 24-7-23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency- MCC Shekhanapur

Village - Mikera kutra Block- Kantha

District- Shekhanapur Logging Depth- 130 mt

Drilling Depth- 135 mt Water Level- 11 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	claystone	
3	10 - 45	Medium Sand	medium
4	45 - 50	claystone	
5	50 - 68	Medium Sand	Medium
6	68 - 81	claystone	
7	81 - 109	Medium Sandstone	medium
8	109 - 118	claystone	
9	118 - 122	Medium Sand	Medium
10	122 - 130	claystone	
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Suresh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.