



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.

Date 22-05-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency- Ncc Shahjahanpur
Village- Raymana Block- Khudair
District- Shahjahanpur Logging Depth- 140 mtr
Drilling Depth- 140 mtr Water Level- 8 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 12	clay Kankar	
3	12 - 20	Fine Sand	
4	20 - 25	clay Kankar	
5	25 - 37	Fine to med. Sand	Good
6	37 - 50	clay Kankar	
7	50 - 77*	medium Sand & Kan.	Good
8	77 - 80	Kankar	
9	80 - 95*	medium Sand	Good
10	95 - 101	clay Kankar	
11	101 - 108*	Fine to med. Sand	Good
12	108 - 113	clay Kankar	
13	113 - 132*	medium Sand & Kan.	Good
14	132 - 135	clay Kankar	
15	135 - 140	Sandy clay	
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V/S
P/R

Geophysicist

Specializations in

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations