



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 26-06-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency-..... NK. Shahyarpur.....
 Village -..... Harsiharpur..... Block-..... Khatam.....
 District-..... Shahyarpur..... Logging Depth-..... 120 mtr......
 Drilling Depth-..... 120 mtr...... Water Level-..... 8 mtr......

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 12	Dry Sand	
3	12 - 18	clay KanKar	
4	18 - 30	medium Sand	Good
5	30 - 35	clay KanKar	
6	35 - 45	medium Sand	Good
7	45 - 53	clay KanKar	
8	53 - 62*	medium Sand	Good
9	62 - 65	clay KanKar	
10	65 - 83*	medium Sand	Good
11	83 - 87	clay KanKar	
12	87 - 93*	medium Sand	Good
13	93 - 96	clay KanKar	
14	96 - 105*	medium Sand	Good
15	105 - 108	KanKar	
16	108 - 118*	medium Sand	Good
17	118 - 120	clay KanKar	
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V. S. P.
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting