

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date...18.9.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency..... NCC Shahjehanpur
 Village - Bhekhanpur Road Block..... Tajpur
 District..... Shahjehanpur Logging Depth..... 128 mtr
 Drilling Depth..... 131 mtr Water Level..... 9 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-20	Sandy clay	
3	20-36	fine Sand	Sand
4	36-55	fine & med Sand	Sand
5	55-60	clay loam	
6	60-90	medium Sand	Sand
7	90-97	Sandy clay	
8	97-103	fine to med Sand	Sand
9	103-105	Sandy clay	
10	105-112	fine to med Sand	Sand
11	112-115	clay	
12	115-128	fine & med Sand	Sand
13			
14			
15			
16			
17			
18			
19			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.