

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date 11.4.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency- N.C.C Ltd Shahjahanpur
Village- Patti Fujharapur Block- madnapur
District- Shahjahanpur Logging Depth- 130 mtr
Drilling Depth- 130 mtr Water Level- 9 mb

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 21	Fine to med sand	
3	21 - 28	clay lenses	
4	28 - 50'	Medium Sand	Med + fair
5	50 - 55	clay lenses	
6	55 - 77'	Medium Sand	Med + good
7	77 - 82	clay lenses	
8	82 - 96'	Medium Sand	Med + good
9	96 - 110	clay lenses	
10	110 - 120'	Medium Sand	Med to good
11	120 - 130	clay lenses	
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Siddhant
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.