

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 14.7.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency Mcc. Shehjanpapur

Village Hareba Block Talababad

District Shehjanpapur Logging Depth 120 mtr

Drilling Depth 120 mtr Water Level 9 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 7	fine sand	
3	7 - 12	clay	
4	12 - 20	fine sand	
5	20 - 26	clay kaolin	
6	26 - 40	Medium Sand	Medium
7	40 - 47	clay kaolin	
8	47 - 70"	Medium Sand	Medium
9	70 - 75	clay kaolin	
10	75 - 81"	Medium Sand	Medium
11	81 - 92	clay kaolin	
12	92 - 118"	Medium Sand	Medium
13	118 - 120	clay kaolin	
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Smit
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.