



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date 16.10.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency- Ncc Shahganhabur
 Village - Sidhanwa Block- Bhawalkhera
 District- Shahganhabur Logging Depth- 110m
 Drilling Depth- 140m Water Level- 4m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 22	fine to med. sand	
3	22 - 33	clay loam	
4	33 - 37	medium sand	Good
5	37 - 42	clay loam	
6	42 - 50	medium sand	Good
7	50 - 60	clay loam	
8	60 - 64	medium sand	Good
9	64 - 73	clay loam	
10	73 - 80	medium sand	Good
11	80 - 82	clay loam	
12	82 - 96	medium sand	Good
13	96 - 102	clay loam	
14	102 - 106	medium sand	Good
15	106 - 110	clay loam	
16			
17			
18			
19			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

S. Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.