



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date. 27-02-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- NCC Shahjahan pwr
 Village - Mahabaganah Block- Pawayan
 District- Shahjahan pwr Logging Depth- 115 mtr
 Drilling Depth- 125 mtr Water Level- 12 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 8	Dry Sand	
3	8 - 23	Fine Sand	
4	23 - 27	clay Kankar	
5	27 - 37	Fine to med Sand	Good
6	37 - 48	clay Kankar	
7	48 - 56*	Fine to med Sand	Good
8	56 - 59	clay Kankar	
9	59 - 68*	medium Sand	Good
10	68 - 73	clay Kankar	
11	73 - 82*	medium Sand	Good
12	82 - 89	clay Kankar	
13	89 - 100*	medium Sand	Good
14	100 - 105	clay Kankar	
15	105 - 110*	medium Sand	Good
16	110 - 115	clay Kankar	
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

U.S.P.
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting.