

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 23.11.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- H.C.C. Shahjahanpur
 Village- Un khurd Block- Muzaffar
 District- Shahjahanpur Logging Depth- 1.05 mtr 1.05 mtr
 Drilling Depth- 110 mtr Water Level- 12 mtr ATP

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	clay loam	
3	10 - 20	Medium Sand	Medium
4	20 - 25	clay loam	
5	25 - 27	Medium Sand	Medium
6	27 - 35	clay loam	
7	35 - 48	Medium Sand	Medium
8	48 - 55	clay loam	
9	55 - 61	fine to med. sand	Medium
10	61 - 69	clay loam	
11	69 - 74	Medium Sand	Medium
12	74 - 89	clay loam	
13	89 - 96	Medium Sand	Medium
14	96 - 110	clay loam	
15			
16			
17			
18			
19			
20			
21			
22			
23			



*Expected Water Bearing Zone

For Ground Water Survey Consultancy

Smit
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.