

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Date... 6.11.22

Ref No.....

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency..... MCC Shahjahanpur
 Village..... P. Chyara Block..... Kanth
 District..... Shahjahanpur Logging Depth..... 128 m
 Drilling Depth..... 130 m Water Level..... 9 m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 25	Sandy clay	
3	25 - 47	Medium Sand	Good
4	47 - 52	clay kankar	
5	52 - 60	Medium Sand	Good
6	60 - 65	clay kankar	
7	65 - 80	Medium sand & clay	Good
8	80 - 89	Kankar Sand	
9	89 - 102	fine to med Sand & clay	Good
10	102 - 107	clay kankar	
11	107 - 109	fine sand	Good
12	109 - 114	clay kankar	
13	114 - 126	Medium Sand	Good
14	126 - 128	Sandy clay	
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

S. Singh
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.