



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 03-06-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency-..... *NCC Shahjahanpur*.....
 Village -..... *Ajya Gaon Mahamadpur* Block-..... *Mahapur*.....
 District-..... *Shahjahanpur*..... Logging Depth-..... *120 mtr*.....
 Drilling Depth-..... *120 mtr*..... Water Level-..... *12 mtr*.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-10	Dry Sand	
3	10-14	clay Kankar	
4	14-25	Fine to med. Sand	Good
5	25-30	clay Kankar	
6	30-42	medium Sand	Good
7	42-47	clay Kankar	
8	47-65*	medium Sand	Good
9	65-72	clay Kankar	
10	72-91*	medium Sand	Good
11	91-95	clay Kankar	
12	95-100*	Fine to med. Sand	Good
13	100-110	clay Kankar	
14	110-120*	Fine to med. Sand	Good
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

UTS
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting.