



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date...03-06-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency-.....MCC Shahjahanp.w.
 Village -.....Saidapur, Raipur..... Block-.....Khudaganj, Kabra.....
 District-.....Shahjahan..... Logging Depth-.....130 mtr.....
 Drilling Depth-.....130 mtr..... Water Level-.....6 mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Fine sand	
3	10 - 20	clay Konkaz	
4	20 - 47	medium sand	Good
5	47 - 55	clay Konkaz	
6	55 - 63*	Fine to med. Sand	Good
7	63 - 70	clay Konkaz	
8	70 - 94*	medium sand	Good
9	94 - 97	clay Konkaz	
10	97 - 111*	medium sand	Good
11	111 - 123	clay Konkaz	
12	123 - 130*	Fine to med. Sand	Good
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

U.P.
Geophysicist

Specializations In