



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date...13-06-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency-.....NCC Shahjahanpur.....
Village -.....Mauaiya Khas..... Block-.....Khudaganj Katna.....
District-.....Shahjahanpur..... Logging Depth-.....120 mtr.....
Drilling Depth-.....120 mtr..... Water Level-.....6 mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 8	clay Kankar	
3	8 - 15	Fine Sand	
4	15 - 22	clay Kankar	
5	22 - 46	Fine to med. Sand	Good
6	46 - 52	clay Kankar	
7	52 - 86*	medium Sand & clay	Good
8	86 - 93	clay Kankar	
9	93 - 98*	Fine to med. Sand	Good
10	98 - 105	clay Kankar	
11	105 - 107	Fine Sand	Good
12	107 - 115	clay Kankar	
13	115 - 118	Fine Sand	Good
14	118 - 120	clay Kankar	
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V/S
Geophysicist

Specializations In