

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date 26.12.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency MCC Shahjehanpur
 Village Dhulva karan Hager Block Taitpur
 District Shahjehanpur Logging Depth 145 mt
 Drilling Depth 150 mt Water Level 8 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 8	clay	
3	8 - 17	fine to med sand	
4	17 - 35	clay kankar	
5	35 - 86	Medium Sand	Good
6	86 - 98	clay kankar	
7	98 - 118	medium sand	Good
8	118 - 121	clay kankar	
9	121 - 129	Medium Sand	Good
10	129 - 135	kankar	
11	135 - 142	Medium Sand	Good
12	142 - 145	clay	
13			
14			
15			
16			
17			
18			
19			



*Expected Water Bearing Zone

For Ground Water Survey Consultancy

Suresh
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.