



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.....

Date 12/02/2024

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency..... NCC Shahjahanpur
 Village - Karhain Block- Khutar
 District- Shahjahanpur Logging Depth- 120 mtr.
 Drilling Depth- 120 mtr. Water Level- 6 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	surface Soil	
2	5 - 15	Dry Sand	
3	15 - 35	clay Kankar	
4	35 - 61	medium Sand	med. to good
5	61 - 67	clay Kankar	
6	67 - 75*	medium Sand	med. to good
7	75 - 81	clay Kankar	
8	81 - 95*	medium Sand	med. to good
9	95 - 100	clay Kankar	
10	100 - 115*	medium Sand	med. to Good
11	115 - 120	clay Kankar	
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

VK
PT
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,