



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 30-04-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency..... NCC, Shahjahanpur.....

Village..... Dahaz Khandahar..... Block..... Salalabad.....

District..... Shahjahanpur..... Logging Depth..... 138 mtr......

Drilling Depth..... 140 mtr...... Water Level..... 6 mtr......

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	clay kankar	
3	10 - 40	Fine to med. Sand	medium
4	40 - 43	clay kankar	
5	43 - 75*	medium Sand	medium
6	75 - 77	kankar	
7	77 - 82*	Fine to med. Sand	medium
8	82 - 92	clay kankar	
9	92 - 110*	medium Sand	medium
10	110 - 138	clay kankar	
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]

Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.