



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
 Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com


Ref No.....

Date 03-06-2023

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency- MC Shahjahanpur  
 Village - Nagarpal Block- Bhawal Khera  
 District- Shahjahanpur Logging Depth- 130.mtu  
 Drilling Depth- 120.mtu Water Level- 9.mtu

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	clay KanKar	
3	10 - 15	Fine Sand	
4	15 - 20	clay KanKar	
5	20 - 31	Fine to med. Sand	Good
6	31 - 54	clay KanKar	
7	54 - 87*	medium Sand & Kan.	Good
8	87 - 94	clay KanKar	
9	94 - 112*	medium Sand & Kan.	Good
10	112 - 120	clay KanKar	
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



\* Expected Water Bearing Zone

For Ground Water Survey Consultancy

*[Signature]*  
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting