

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 27.10.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency- N.C.C. Shahjahanpur

Village - Ahiadadpur Block- Talababad

District- Shahjahanpur Logging Depth- 110 mts

Drilling Depth- 110 mts Water Level- 3 mts Atp.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-10	clay	
3	10-20	Medium Sand	Medium
4	20-25	clay layer	
5	25-36	Medium Sand	Medium
6	36-40	clay layer	
7	40-43	Medium Sand	Medium
8	43-57	clay layer	
9	57-79	Medium Sand	Medium
10	79-95	clay layer	
11	95-97	fine Sand	Medium
12	97-110	clay layer	
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.