

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 26.10.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- MCC Ltd Shahjahanpur
 Village - Sarai Block- kehter
 District- Shahjahanpur Logging Depth- 120 mtr
 Drilling Depth- 120 mtr Water Level- 6 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 15	clay loams	
3	15 - 25	Medium Sand	Medium
4	25 - 30	clay loams	
5	30 - 38	Medium Sand	Medium
6	38 - 50	clay loams	
7	50 - 62	Medium Sand	Medium
8	62 - 68	clay loams	
9	68 - 81*	Medium Sand	Medium
10	81 - 90	loams	
11	90 - 100*	Medium Sand	Medium
12	100 - 108	clay loams	
13	108 - 115*	Medium Sand	Medium
14	115 - 120	clay loams	
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Smit
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.