

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 10.6.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- NCC Shahjahanpur
 Village - Zarainpur Block- Muzaffarpur
 District- Shahjahanpur Logging Depth- 140 mt
 Drilling Depth- 140 mt Water Level- 9 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Snt	
2	5 - 20	clay loam	
3	20 - 40	Medium Sand	Med + grnd
4	40 - 52	clay loam	
5	52 - 64	Medium Sand	Med + grnd
6	64 - 70	clay loam	
7	70 - 75	Medium Sand	Med + grnd
8	75 - 105	clay loam	
9	105 - 129	Medium Sand	Med + grnd
10	129 - 134	clay loam	
11	134 - 136	fine Sand	Med + grnd
12	136 - 140	clay loam	
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.