

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No.....


Date 23.5.22

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency... MCC Shaljanapur  
 Village... Mudiyakhora Firozabad Block... Jaitipur  
 District... Shaljanapur Logging Depth... 117 mtr  
 Drilling Depth... 130 mtr Water Level... 6 m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 20	Fine Sand	
3	20 - 25	Clay loam	
4	25 - 39	Medium Sand	Medium
5	39 - 41	Clay loam	
6	41 - 51	Medium Sand	Medium
7	51 - 56	Clay loam	
8	56 - 74	Medium Sand	Medium
9	74 - 81	Clay loam	
10	81 - 75	Medium Sand clay	Medium
11	75 - 81	Clay loam	
12	81 - 95	Medium Sand clay	Medium
13	95 - 103	Clay loam	
14	103 - 112	Medium Sand	Medium
15	112 - 117	Clay loam	
16			
17			
18			
19			
20			
21			
22			
23			



\* Expected Water Bearing Zone

For Ground Water Survey Consultancy

*S. Singh*  
Geophysicist

### Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.