

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date. 16.7.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency- HCC Shajhanpur

Village- Pathrajpur Block- Nigohi

District- Shajhanpur Logging Depth- 120 m

Drilling Depth- 120 m Water Level- 8 m

| S.No | Depth in Mtr. | Lithology | Expected Water Quality |
|------|---------------|--------------|------------------------|
| 1 | 0-5 | Surface Soil | |
| 2 | 5-18 | Chalk | |
| 3 | 18-28 | fine Sand | |
| 4 | 28-35 | Chalk | |
| 5 | 35-45 | Medium Sand | Medium |
| 6 | 45-48 | Chalk | |
| 7 | 48-58 | Medium Sand | Medium |
| 8 | 58-65 | Chalk | |
| 9 | 65-71 | Medium Sand | Medium |
| 10 | 71-80 | Chalk | |
| 11 | 80-103 | Medium Sand | Medium |
| 12 | 103-108 | Chalk | |
| 13 | 108-117 | Medium Sand | Medium |
| 14 | 117-120 | Chalk | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |
| 21 | | | |
| 22 | | | |
| 23 | | | |



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.