

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 18.10.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- NCC Ltd Shahjahanpur
Village - Navadiya Horiba Block- Khatav
District- Shahjahanpur Logging Depth- 120 mt
Drilling Depth- 120 mt Water Level- 4.5 mt Abb

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 14	clay layer	
3	14 - 25	Medium Sand	Medium
4	25 - 30	clay layer	
5	30 - 37	Medium Sand	Medium
6	37 - 43	clay layer	
7	43 - 46	Medium Sand	Medium
8	46 - 52	clay layer	
9	52 - 65'	Medium Sand	Medium
10	65 - 70	clay layer	
11	70 - 81'	Medium Sand	Medium
12	81 - 85	clay layer	
13	85 - 101'	Medium Sand	Medium
14	101 - 108	clay layer	
15	108 - 115'	Medium Sand	Medium
16	115 - 120	clay layer	
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.