



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 02-05-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency..... MCC Shah jahan pur
Village..... Nandara Block..... madnapur
District..... Shahjahanpur Logging Depth..... 120 mtr.
Drilling Depth..... 120 mtr. Water Level..... 9 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-28	clay Kankar	
3	28-50	medium Sand	Good
4	50-55	clay Kankar	
5	55-68*	medium Sand	Good
6	68-72	clay Kankar	
7	72-95*	medium Sand & Kam	Good
8	95-101	clay Kankar	
9	101-110*	medium Sand	Good
10	110-114	clay Kankar	
11	114-120*	medium Sand	Good
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.