



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 28/01/2024

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- NCC Shahjahanpur
 Village - Singhapur Block- Lowyan
 District- Shahjahanpur Logging Depth- 130 mtr
 Drilling Depth- 130 mtr Water Level- 8 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 8	clay KanKar	
3	8 - 16	Fine sand	
4	16 - 22	clay KanKar	
5	22 - 36	medium sand	med. to good
6	36 - 43	clay KanKar	
7	43 - 48	medium sand	med. to good
8	48 - 57	clay KanKar	
9	57 - 67*	medium sand & Kan.	med. to good
10	67 - 74	clay KanKar	
11	74 - 80*	Fine to med sand	med. to good
12	80 - 90	clay KanKar	
13	90 - 105*	Fine to med sand	med. to good
14	105 - 111	clay KanKar	
15	111 - 130*	Fine to med. sand & Kan.	med. to good
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

VK
8/3
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Discharge Well, Rectification of Tubewells, Ground Water Investigation