


## COMPLETION PLAN OF TUBEWELL

**Name of work** :- Construction of T. W. of G.P. Ghoghulpur, Block-Bhejam, District, Lakhimpur Kheri.  
**Name of Program** :- J. J. M-2  
**Name of client** :- S.W.S.M. & U.P. JAL NIGAM ( R)  
**Name of Contractor** :- M/S NCC Limited  
**Name of TPI** :- Ceinsys Tech Limited  
**Contract Agreement** :- 64/ED/2020-21 Dt. 12.03.2021  
**Cover Agreement** :- 200/ED/2021-22/III Dt. 30 November 2021

Lowered Assembly Chart of T. W of Goghulpur Bujurg G.P W/S Scheme District :- Lakhimpur Kheri.

### Strata

0-3 mtr Surface Clay
3-28 mtr Clay & Silty Clay.
28-42 mtr Fine Sand
42-47 mtr Clay
47-90 mtr Fine Sand
90-96 mtr Sandy soil
96-128 mtr Fine to Medium Sand
128-140 mtr Clay with Kankar
140-150 mtr Fine to Medium Sand
150-155 mtr Sandy soil with Caving Clay
155-160 mtr Medium Sand
160-162 mtr Sandy soil with Kankar



ABSTRACT	
1	Type of Rig Machine :- DC Cum RC
2	Static Water level :-
3	Required Discharge :- 750 LPM
4	Bore Size (MM) :- 600x450
5	Assembly Size (MM) :- 300 x 150
6	Drilling Starting Date :- 31.01.2022
7	Drilling Completion Date :- 05.02.2022
8	Total Depth Of Drilling :- 166M
9	Logging Date :- 06.02.2022
10	Logging Depth :- 162M

Logging Report By Aqua Xplore Lucknow			
Sl.No	Depth (mbgl)	Thickness (m)	Remarks
1	28-42	14	Fine to Medium Sand (Good All)
2	47-90	43	
3	96-128	32	
4	140-150	10	
5	155-160	5	

Note:-Sl. No. 5 is Fine Sand

11. Details of Lowered Assembly	
i) 300 mm Dia Housing Pipe	:- 48.0 Meter
ii) 150 mm Dia M. S. Slotted pipe	:- 30.01 Meter
iii) 150 mm Dia M. S. Plain pipe	:- 54 Meter
iv) 300 x 150 mm Dia M S Reducer	:- 0.20 Meter
Total :- 132.21 Meter	
AGI :- 00.50 Meter	
BGL :- 131.71 Meter	
12. Date of Lowering	:- 08.02.2022

Recommended & Prepared by

*Boave*  
NCC LIMITED

Verified by

*Boave*

Recommended by

*W.K. Stolar*  
J.E

13th Division UP Jal

*Boave*  
A.E

13th Division UP Jal

Approved by

*Boave*  
E.E

13th Division U.P Jal Nigam

Ref: NCC/SWSM/LKO-DIV/Lakhimpur-Kheri/0206/2022-23

Date: 04.05.2022

To,  
The Research Officer,  
Central Water Testing Lab  
UP Jalnigam, 6 Rana Pratap Marg,  
Lucknow

Sub: Survey, Design, Preparation of DPR Construction, Commissioning and O&M for 10 years of various Rural Water Supply Projects (JJM) in the State of Uttar Pradesh – Lakhimpur Kheri District – Submission of Water Sample of Tube well for Testing Purpose - Reg.

Ref.: 1) LOI No: 2143/W-22/NIT/2021-21, dated 13.01.2021  
2) ED-SWSM Letter No: 2304/W-22/NIT/2020-21, dated 21.01.2021  
3) DM office-Kheri Letter no: 807/L.C./JJM/2020-21, dated 27.02.2021  
4) Contract Agreement no: 64/ED/2020-21, dated 12.03.2021


Dear Sir,

With reference to the above subject, we are herewith submitting the water sample of Tubewell for testing purpose of Ghoghulpur bujurg Gram Panchayat, Behjam Block, Lakhimpur Kheri District.

Hence, kindly arrange the Water Testing as per enclosed parameters.

Thanking you and assuring of our best services at all times.

Yours faithfully,  
For NCC Limited

  
BSS Mallikarjuna  
Project Manager  
SWSM-JJM Works  
Lakhimpur Kheri

Encl: As above

Copy to: 1) The Executive Engineer, UP Jal Nigam, Lakhimpur Kheri.  
2) The Executive Engineer, E&M Jal Nigam, Lucknow division.  
3) The TPI (M/s Ceinsys Tech Ltd), Lakhimpur Kheri.

Letter & Sample  
Received  
Abhishek  
04/05/2022

  
NCC Limited

(Formerly Nagarjuna Construction Company Limited)

CIN : L72200AP1990PLC011146

Site Office : SWSM Project Lakhimpur-Kheri, Vill Demoura, Baba Ganj Chauraha, Near Opposite Manu Law College, Sitapur-Lakhimpur Road,  
District - Lakhimpur-Kheri (U.P.)-262725

Regional Office : Ansal API, Sector - C 2/183, Sushant Golf City, Near S.J. International School, Shaheed Path, Lucknow - 226 030.

Mob. : 9140075181, 8123012220

E-mail : bldgs.swsमुपलपुर@nccLtd.in | mallikarjuna.b@nccLtd.in | Web. : www.ncclimited.com