


Allahpur Khurd & Nehdali G.P. wss Under JIM Programme
Block - Asappur Distt - Budaun

D - 130m (600 x 450) mmφ
 L - 120m (300 x 150) mmφ

Dt - 29/09/2023
Discharge - 760 LPM
47m Head 15 HP

Staata As per Logges -

56-87m - medium Sand
 93-100m - medium Sand



300 mmφ (H.P)	150 mmφ (P-P)	150 mmφ (S-P)
6.00	6.00	6.00
6.00	6.00	6.00
6.00	6.00	6.00
6.00	3.00	6.00
6.00	6.00	6.00
6.00	6.00	3.00
6.00	6.00	3.00
6.00	6.00	1
<u>48.00m</u>	<u>33.00m</u>	<u>24.00m</u>

300 mmφ (H.P) = 48.00m
 150 mmφ (P-P) = 33.00m
 150 mmφ (S-P) = 24.00m
 (300 x 150) mmφ Red = 0.15m
Total = 105.15m

A.G.L = 0.50m
 B.G.L = 104.65m
Total = 105.15m

6.00	11		
6.00	10		
3.00	9	(Ch)	62.65m
6.00	8		
6.00	7		
6.00	6		
3.00	5		83.65m
6.00	4	(Ch)	
6.00	3	(Ch)	95.65m
3.00	2		98.65m
6.00	1	(Ch)	104.65m
		150 mmφ	

[Signature]

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTROLOGGING REPORT**

Ref No:-A-1705

Date:- 28-09-2023

NAME OF SITE

GRAM PANCHAYAT- Allahpur Khurd BLOCK- Asafpur DISTT- Badaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- ALLAHPUR KHURD, BLOCK- ASAFPUR, DISTT- BADAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 130 mtrs. depth. and Logged depth 130 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 28.Sep.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 15	10	Dry sand	
3.	15 - 30	15	Clay kankar	
4.	30 - 37	7	Medium sand	Medium
5.	37 - 42	5	Clay kankar	
6.	42 - 48*	6	Medium sand	Medium
7.	48 - 56	8	Clay kankar	
8.	56 - 87*	31	Medium sand	Medium
9.	87 - 93	6	Clay kankar	
10.	93 - 100*	7	Medium sand	Medium
11.	100 - 120	20	Clay kankar	
12.	120 - 128*	8	Medium sand	Medium
13.	128 - 130	2	Clay kankar	

Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a
 NI 6 (SN)
 NI 4 (LN)
 LAT
 Logging Details
 Logging GP Analyser Model
 Root Analyser Data Station
 UP ICGR/NGQP
 28 Sep 2013
 1953
 Uthmaniyah Geom (AG)

Logger SN No:
 IGIS/SV02/ZZ-23

Logger Model:
 SP (m V)

Logger Model:
 DMPL-2

Logger Owned by:
 GROUND WATER
 SURVEY
 CONSULTANCY
 AGRA, UP, INDIA

