



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 202008
 Mob 9761163000, 9794625420, Email gwr_agra@yahoo.com

Ref No


Date 17.11.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- NKG Infrastructures Ltd. Galaji Trolins Rampur
 Village- Madaxpur Block- Shahbad
 District- Rampur Logging Depth- 146 mtr
 Drilling Depth- 150 mtr Water Level- 6 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 20	Fine Sand	Good
3	20 - 25	clay kanker	
4	25 - 35	Fine to med sand	Good
5	35 - 41	clay kanker	
6	41 - 63	Medium Sand	Good
7	63 - 70	clay kanker	
8	70 - 86	Medium Sand	Good
9	86 - 96	clay kanker	
10	96 - 105	Fine to Med Sand	Good
11	105 - 112	clay kanker	
12	112 - 117	Medium Sand	Good
13	117 - 128	clay kanker	
14	128 - 137	Medium Sand	Good
15	137 - 146	clay	
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations