

Fatanpurja Tappa Haveli G.P w/s Scheme Under JTM Prog-
Block - Saharwan Distt - Budaur

DT-05/01/2022

Discharge - 417 LPM

36M Head 7.5 H.P

Strata As Per Logger -

52-60m - Medium Sand

65-75m - Medium Sand

85-97m - Medium Sand

D-110m (500x500)mmφ


L-100m (200x150)mmφ

← 200mmφ →

200mmφ (HP)	150mmφ (P.P)	150mmφ (SP)
6.00		
6.00	6.00	5.00
6.00	6.00	6.00
6.00	6.00	1.00
6.00	2.00	5.00
6.00	6.00	
6.00	6.00	17.00m
42.00m	1.00	
	5.00	
	38.00m	

200mmφ (HP) = 42.00m
 150mmφ (P.P) = 38.00m
 150mmφ (SP) = 17.00m
 (200x150)mmφ Red = 0.15m
Total = 97.15m

A.G.L = 0.50m
 B.G.L = 96.65m
Total = 97.15m



← 150mmφ →

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTOLOGGING REPORT

Ref No:- 575

Date:- 04-01-2023

NAME OF SITE

Gram Panchayat- Fatanpurya Tappa Havelli
DISTT- Budaun

BLOCK- Sahaswan

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- FATANPURYA TAPPA HAVELLI, BLOCK- SAHASWAN,
DISTT.- BUDAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 110 mtrs. depth. and Logged depth 110 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 04.Jan.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 12	7	Dry sand	
3.	12 - 23	11	Clay kankar	
4.	23 - 32	9	Medium sand	Medium
5.	32 - 52	20	Clay kankar	
6.	52 - 60*	8	Medium sand	Medium
7.	60 - 65	5	Clay kankar	
8.	65 - 75*	10	Medium sand	Medium
9.	75 - 85	10	Clay kankar	
10.	85 - 93*	8	Medium sand	Medium
11.	93 - 100	7	Clay kankar	
12.	100 - 108*	8	Medium sand	Medium
13.	108 - 110	2	Sandy clay	

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations

Geophysicist



Ground Water Survey Consultancy

